



Test Water Before Taste
Tamilnadu Water Supply and Drainage Board
District Water Testing Laboratory -Karur

From :
Thiru.V.Srinivasan BE
Assistant Executive Engineer
TWAD Board.,
DWT Lab, Karur

To :
Pon Vidya Mandir
SF. No.175, NH-7, Manmangalam
Karur -639006

Lr.No. 153 /JWA/TWAD Lab/KRR/ 2026-27 dated : 22.06.26

Sir,

Sub: Examination of water samples - Report furnished reg.

1)T.O Invoice No.5861 /dt 18.06.26 /Rs.1652 /-

2)DD.No: 783550/dt 18.06.2026 ,Rs 1652/ SBI,Karur

The results of the Water sample tested under reference is furnished below:

Lab No.			153
Date of Collection:			18.06.2026
Date of Receipt :			18.06.2026
Location of Sampling			Inside The Campus
Habitation for source			Manmangalam
Panchayat			Manmangalam
Union			Karur
Source			RO Water
BIS 10500 : 2012			
I. PHYSICAL EXAMINATION.	Acceptabl e limit	Permissible limit in the absence of alternate source	153
1. Appearance	-	-	Clear
2. Colour (pt.co-scale)	5	15	Colourless
3. Odour	Agreeable	Agreeable	None
4. Turbidity NT Units	1	5	0
5. Total dissolved Solids mg/L	500	2000	36
6. Electrical Conductivity Micro mho/cm	-	-	51
II.CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	6.73
8. Ph. Alkalinity as CaCO ₃ mg/L	-	-	0
9. Total Alkalinity. as CaCO ₃ mg/L	200	600	8
10. Total Hardness as CaCO ₃ mg/L	200	600	12
11. Iron as Fe mg/L	0.3	0.3	0
12. Nitrate as NO ₃ mg/L	45	45	0
13. Chloride as Cl mg/L	250	1000	11
14. Fluoride as F mg/L	1.0	1.5	0.0
15. Sulphate as SO ₄ mg/L	200	400	0
16.Free Residual Chlorine mg/L	0.2	1.0	0.00
III. BACTERIOLOGICAL EXAMINATION:			
1.Fecal Coliform (Colonies Per 100 ml)	0	0	0

REPORT: 153 The Water is Physically , Chemically **Potable** and Bacteriologically

Not Contaminated with respect to to the tested parameters,

22/06/26
Assistant Executive Engineer,
TWAD-RWS Sub Division,
KARUR

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 153 / JWA / TWAD Lab / KRR / 2026 - 2027

Date : 25.06.2026

It is certified that an inspection team headed by **N.KANNAN**

BLOCK HEALTH SUPERVISOR, GOVT PRIMARY HEALTH CENTER, VANGAL

From the Department of Public Health and Preventive Medicine inspected the

PON VIDYA MANDIR SF.No. 175, NH-7, Manmangalam , Karur – 639 006.

on **25.06.2026** and on the basis of water Test Report bearing No 153 / JWA / TWAD Lab /
KRR / 2026 – 2027 dated 22.06.2026 of Tamil Nadu water Supply and Drainage Board,

Karur. Certified that the **PON VIDYA MANDIR** has safe Drinking water

facilities for the Students and Staff members of the Institution. School is also


Maintains the hygienic sanitation condition in the School Building & the Campus as per the

Norms prescribed by the Central / State / U.T. Government.

The Certificate is Valid till dated of issued from one year

To

The Correspondent ,
PON VIDYA MANDIR,
SF.No. 175, NH – 7,
Manmangalam ,
Karur- 639 006.

15a. 
25.6.2026
Block Health Supervisor
Government Primary Health Centre,
Vangal-639 116.
Karur Dist.